

1. Water treated for the month of July was 2,552,400 gallons. Water treated for the month of June was 2,166,100 gallons. Usage was up approximately 17% from last month and down 31% from the same time last year. This lower usage this year compared to same time last year is due to the cooler summer that we are having as well as vacant homes.
2. Sewage treated for the month of June was 278,371 gallons and for the month of July the amount treated was 294,714 gallons.
3. Still no update on the blending of Well #2 and #3 by the Department of Public Health.
4. Foothill Sanitary Septic Pumping came out on July 19, 2010 and pumped out the solids tank at the Wastewater Treatment Plant. Foothill hauled two loads of solids out to CCWD's LaContenta Wastewater Treatment Plant.
5. Both prominent chemical pumps (one for the chlorine at the WWTP and one for the KMNO₄ at the WTP) had to be repaired. Rebuilt kits were ordered and the necessary repairs were made. However, we will be ordering a spare chemical pump to keep on hand.
6. There is a problem with the auto backwash at the WWTP. The electricians will be troubleshooting the situation. The PLC (Programmable Logical Control) is a very old unit made by Texas Instruments. We have a few parts but this particular PLC is obsolete. Currently the operators are backwashing manually until the electricians have time to trace the wiring and perform an extensive electrical analysis on the PLC and pressure switch.
7. The Lead and Copper samples are complete. Wallace is required to test only 5 sites that were determined by the age of the house and the plumbing. Test

results have not been received. The District is required to sample for Lead and Copper every three years. The lab results will be made available to the homeowner's who participated as well as on next year's Annual Water Quality Report.